

21.05.2025

Welcome to TriOS



Short introduction

21.05.2025

2

2011



2016



2019



Founded in 1998

2011: TriOS moved to Rastede with 20 employees

Currently ~100 employees



Sustainability: Solar Panels, geothermal energy, natural habitats and recycling

Portfolio

Photometer



Radiometer



Fluorometer



Controller




eCHEM



Zubehör



Nephelometrie



Systeme



RAMSES >1900 devices since 1998

21.05.2025

5

ACC-VIS



VIS irradiance

ARC-VIS



VIS radiance

For the 20th anniversary
RAMSES got new features like
G2 webbrowser
Modbus RTU
+ internal temperature sensor
+ inclination sensor for 360° for
x, y, z axes (no up and down)

We service sensors sold in 2002
until today

- Very long lifetime
- traceable history of calibrations and repairs

Calibration and Interfaces

21.05.2025


6

	RAMSES
Calibration	NIST Standard Traceability Calibrated DXW-1000 W (max. running time 50 hours)
Temperature	Darkpixel compensation Internal Temperature <small>not yet implemented into calibration</small>
Interfaces	RS-232 or RS-485 Modbus RTU & Ethernet available

Calibration: Irradiance

21.05.2025

7



Static procedure

Room temperature between 21°C and 24°C

Distance measured with a ruler and laser beam

Reference sensor

Warm-up time lamp until stable readings @8 A

Warm-up time sensor: 16 measurements

Calibration sensor: 16 measurements

Scatter: 16 measurements


Water calibration (cosine collector fully covered with water):
directly after air calibration 16 measurements

Scatter: 16 measurements

Calibration: Radiance

21.05.2025

8



Static procedure since 2007
Room temperature between 21°C and 24°C
Reference sensor

Warm-up time lamp until stable readings @8 A

Warm-up time sensor: 16 measurements

Calibration sensor: 16 measurements

Scatter: 16 measurements

Water calibration: theoretical (Ohde und Siegel, 2003)


$$n_g(\lambda) = 1.4424 + \frac{7.1661}{\lambda - 144.7170}$$

Refraction index: 1.460082 @550 nm

Traceability since 2007 until 2024

21.05.2025

9




Device type:
ARC (radiance)

Traceability since 2007 until 2024

21.05.2025


10



Calibration: dark measurements

21.05.2025

11




Calibration: dark measurements

21.05.2025

12


SAM_86AB - 4096 ms - 2020-11-23 09:43:42
Ungefiltert: Mittel = 1735, RB = 40 (39.9), RMS = 5.71
Ausserliegende = 4, Steigung = 0.021
Gefiltert: Mittel = 1735
Gelb: - Rot: Ausserhalb ≥ 3



Calibration: dark measurements

21.05.2025

13



Calibration and Characterisation

21.05.2025

14

Table 3.1. Basic requirements on the type and occurrence of calibrations and main characterizations of field radiometers supporting ocean color validation activities.

	Regular	Occasional	Initial	Class-based
Radiometric responsivity	X			
Spectral response		X		
Out-of-band & stray light		X		
Immersion factor (irradiance)			X	
Immersion factor (radiance)				X
Angular response			X	
Linearity				X
Integration time				X
Temperature response				X
Polarization sensitivity				X
Dark-signal	X			
Temporal response				X
Pressure effects				X



specified by Carl Zeiss



theoretical

on request (since 2016 new material)



(on request)



dark pixel, specified by Carl Zeiss





Source: IOCCG Protocol Series (2019). *Protocols for Satellite Ocean Colour Data Validation: In Situ Optical Radiometry*. Zibordi, G., Voss, K. J., Johnson, B. C. and Mueller, J. L. IOCCG Ocean Optics and Biogeochemistry Protocols for Satellite Ocean Colour Sensor Validation, Volume 3.0, IOCCG, Dartmouth, NS, Canada.

Characterisation: Angular response

21.05.2025

15





As the graphic shows, **a change of temperature T does not cause any change in sensitivity**. In the range up to 1100 nm, the sensitivity even increases as the temperature rises. At temperatures between - 50 and + 50 °C, the sensitivity changes by less than 1% in the range of 1 to 1.55 μm , even for InGaAs photodiode arrays. Only outside of the specified range is a stronger temperature influence caused by a different coating. (Falling temperatures cause reduced sensitivity on the band edge.) The photodiode arrays used do not show any deterioration in the signal-to-noise ratio. Only the dark current I_{dark} increases with rising temperature, resulting in a reduction of the dynamic range.

Characterisation: Conclusion

21.05.2025

17

Spectral response

performed by Carl Zeiss in advance

Stray light matrix

done during every calibration

Determination of immersion factors for irradiance sensors

done during every calibration

Determination of immersion factors for radiance sensors

theoretical (Ohde & Siegel, 2003)

Determination of angular response of irradiance sensors in air

available on request

Measuring FOV of the radiance sensors in air

available on request

Determination of the non-linearity

not available

Determination of the dark signal

done during every calibration (all IT's)

Determination of the thermal sensitivity

specification by Carl Zeiss

Determination of the polarisation sensitivity

not available

Determination of the temporal response

not available

Determination of the wavelength scale

performed by Carl Zeiss in advance




Determination of the signal-to-noise ratio

specified by Carl Zeiss

RAMSES Technical specification

21.05.2025

18

	ACC			ARC	ASC
					
	UV	UV/VIS	VIS	VIS	VIS
Wavelength range* [nm]	280...500	280...720	320...950	320...950	320...950
Detector*	256 Channel silicon photo diode array				
Pixel dispersion* [nm/pixel]	2.2	2.2	3.3	3.3	3.3
Wavelength accuracy*	0.2	0.2	0.3	0.3	0.3
Usable channels	100	200	190	190	190

	ACC-UV	ACC-VIS	ARC-VIS	ASC-VIS
	UV A / UV B irradiance	VIS irradiance	VIS radiance	VIS scalar irradiance
Wavelength range*	280...500 nm	320...950 nm		
Type Saturation (IT: 4 ms)**	20 W m ⁻² nm ⁻¹ (at 300 nm) 17 W m ⁻² nm ⁻¹ (at 360 nm) 18 W m ⁻² nm ⁻¹ (at 500 nm)	10 W m ⁻² nm ⁻¹ (at 400 nm) 8 W m ⁻² nm ⁻¹ (at 500 nm) 14 W m ⁻² nm ⁻¹ (at 700 nm)	1 W m ⁻² nm ⁻¹ sr ⁻¹ (at 500 nm)	20 W m ⁻² nm ⁻¹ (at 400 nm) 12 W m ⁻² nm ⁻¹ (at 500 nm) 15 W m ⁻² nm ⁻¹ (at 700 nm)
Type NEI**** (IT: 8 s)	0.85 μW m ⁻² nm ⁻¹ (at 300 nm) 0.75 μW m ⁻² nm ⁻¹ (at 360 nm) 0.80 μW m ⁻² nm ⁻¹ (at 500 nm)	0.4 μW m ⁻² nm ⁻¹ (at 400 nm) 0.4 μW m ⁻² nm ⁻¹ (at 500 nm) 0.6 μW m ⁻² nm ⁻¹ (at 700 nm)	0.25 μW m ⁻² nm ⁻¹ sr ⁻¹	0.8 μW m ⁻² nm ⁻¹ (at 400 nm) 0.6 μW m ⁻² nm ⁻¹ (at 500 nm) 0.8 μW m ⁻² nm ⁻¹ (at 700 nm)
Collector	Kosinus		FOV: 7° in air	Spherical, 2 Pi
Accuracy	Better than 6...10% ***		Better than 6% ***	Better than 5% ***
Integration time	4 ms...8 s			

*) Specifications of Carl ZEISS AG, Germany **) Integration time ***) Depends on wavelength range ****) Noise-equivalent irradiance

Temperature compensation

New generation of RAMSES has an internal temperature sensor

Thank you!

Questions?